



K.Dis.No.2747/C1/2023
Dated.24.03.2023.

31/3/23
25/1

O/o.the Director of Fire & Rescue Service,
No.17, Rukmani Lakshmi pathi Salai,
Egmore, Chennai – 600 008.

Licence No.167/2023 (Renewal)

Ref: (1) Letter from the **M/s. Kalaingar Karunanidhi Institute of Technology, Coimbatore,**
Dated:16.02.2023.

(2) Letter R.C.No.817/A2/2023, dated.14.03.2023 from
the Chairman, MSB Inspection Committee, **Western Region, Coimbatore.**

With reference to the letter first cited above the Fire Licence is **renewed** as under, based on the recommendations conveyed in the reference 2nd cited above.

FIRE & RESCUE SERVICES LICENCE

The Fire Licence is hereby **renewed** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for the multi-storied building classified as **Group B Educational Building, Sub-Division B-2 Other Institution of M/s. Kalaingar Karunanidhi Institute of Technology,** educational institution consists of west and east blocks. Each block consists of a ground floor + 4 floors with the height of 19.08 meters at **S.F.No.282/1, 283/1, Pappampatti Privu, Kannampalayam, Suler - Coimbatore** subject to the following conditions and such other conditions as may be prescribed from time to time. This licence is valid for **ONE YEAR** from **24.03.2023 to 23.03.2024** and should be renewed on **24.03.2024.**

CONDITIONS

1. Periodical maintenance should always be ensured to keep all fire protection equipment and systems in good working condition.
2. "Mock drill" should be periodically conducted. The date of conduct should be informed to the District Officer, Coimbatore District well in advance to enable the team to make suggestions, if any.
3. Trained fire personnel should be available to operate the systems in case of any emergency.

4. All fire fighting equipment should always be kept in good working condition at all times.
5. Any erection of a permanent or temporary structure should be intimated to this Fire and Rescue Services Department.
6. With reference to air-conditioning it should not exceed the electricity board load on any account.
7. Available set back area 7 meters on all sides should be maintained to withstand the weight of 45 tons of fire fighting vehicle.
8. House keeping / dumping of waste material any where should be avoided. Dust bins should be cleared everyday.
9. Emergency fire exit, door should open from the floor to staircase only and not the other way round. The door should be in red reflector & arrow marks should commensurate with the gradient of staircase.
10. Do's & don'ts in times of emergencies should be available in a laminated hanging pad or otherwise in the telephone operator's desk as well as in the CE or emergency in charge of the officer's desk.
11. Alternate staircase should be kept free without any obstruction.
12. All staircases should be kept open during office hours and should be kept usable at any point of emergency.
13. Fire order / contingency plan should be prepared and displayed in each floor. It should also contain the rescue team members name, designation and contact number.
14. As per section 3.2 of BIS 12459, 1988 - code of practice for fire safety in cable regularization, 1 m transparent fire retardant coatings shall be applied to all cables at termination points in electrical panels and all cables inside the distribution boxes.

Abhash Kumar,
Director.

To:

M/s. KIT - Kalaigarkarunanidhi Institute of Technology,
Vijayalakshmi Palanisamy Charitable Trust,
Kannampalayam Post, Coimbatore - 641 402.

Copy to:

The Joint Director, Fire and Rescue Services,
Western Region, Coimbatore.

//Forwarded by Order//

சி. 2306.7 2013
Additional Director,
Fire and Rescue Services,
Tamil Nadu.

